

Facility Name _____ Date _____

Contact Name _____ Title _____

Facility Address _____ Phone (____) _____

City _____ State _____ Zip Code _____

RETAIL FIREWORKS INSPECTIONS – 01F

(RETAIL STAND FIRE SAFETY FEATURES)

Kansas State Fire Marshal Retail Stand Fireworks Inspection Checklist - 01F

Item	Safety Feature	Met	Not Met	Comments
01F-01	Permitted Sale Dates			
01F-02	Discharge/100' Place Inst.			
01F-03	Discharge/Vehicles			
01F-04	Discharge/Roadways			
01F-05	Discharge/100' Stand			
01F-06	Illegal Fireworks			
01F-07	Records			
01F-08	Permitted By Law			
01F-09	Fire Extinguishers			
01F-10	Attendant On Duty			
01F-11	No Smoking Sign			
01F-12	Storage/Gasoline/Liquids			

- ♦ *Under K.A.R. 22-6-20, the Kansas State Fire Marshal's Office has adopted NFPA 1124 (2006 edition).

Retail Fireworks Checklist Item Information

Item 01F-01 >> 22-6-5. Permitted Sale Dates

Sale of fireworks not permitted before June 27th and not after July 5th

Item 01F-02 >> 22-6-9. Discharge/100 Feet From Any Place of Institution

Fireworks not permitted to be discharged within 100 feet from any place of institution.

Item 01F-03 >> 22-6-9. Discharge From/Under Vehicles

Fireworks are not permitted to be discharged from, into, under, or on any vehicle whether it is moving or standing.

Item 01F-04 >> 22-6-9. Discharge/Roadway

Fireworks are not permitted to be discharged on a public roadway or the right-of-way adjoining a public roadway.

Item 01F-05 >> 22-6-9. Discharge/100 Feet From Retail Stand and Storage Area

Fireworks are not permitted to be discharged within 100 feet of any retail stand or facility where fireworks are stored.

Item 01F-06 >> 22-6-12 Illegal Fireworks

Refer to checklist item **01F-08**, if not met notify KSFMO immediately, confiscate fireworks, and complete seized fireworks receipt. Give copy of Kansas Statutes and Regulations sheet to retail stand representative.

Item 01F-07 >> 22-6-18 Records

Each operator of a temporarily retail stand shall maintain a list of what consumer firework items are on the premises, indicating the Kansas licensed distributor from whom those items were purchased.

Item 01F-08 >> K.S.A. 31-155. Permitted By Law

Bottle Rockets and Skyrockets are not permitted.

Item 01F-09 >> 7.3.6.3*; 7.6.2.1* Fire Extinguishers

Two portable fire extinguishers with a minimum rating of 2A. One must be pressurized water type.

OR

Fireworks stands less than 200 square feet are only required to have one portable fire extinguisher.

Item 01F-10 >> 7.5.1.2*. Attendant On Duty

Fireworks shall be under supervision of store employee while open to the public.

Item 01F-11 >> 7.3.11.2*. No Smoking Sign

Posted sign reads "FIREWORKS - NO SMOKING". Sign shall be 2in. high on a contrasting background. Posted at each entrance or within 10 feet of every aisle.

Item 01F-12 >> 7.3.12.2*. Storage/Gasoline/Liquids

Must be at least 50 feet from motor vehicle fuel-dispensing station.